

					
STATE PUBLIC HEALTH LABORATORY, PUNE					
Dy Director tele No. 26330509 (P) Office Tele No. 26330225 (O)		Cantonment water works campus, Near Saint Mary Church, Staveley road, Pulgate, Pune-411 001 (MH) INDIA Email ID : sphlmis@gmail.com , statehealthlab@gmail.com website : arogya.maharashtra.gov.in			
HEALTH SERVICES:		No.SPHLPUNE/Dask-80/Bact.Section/water analysis report/ 383 / 2026 Date : 14/05/2026			

Bacteriological Report of water Sample

Sender's Name	Orchids – The International School, Swargate, Pune, Maharashtra
Sendr's letter No. & date	-/ 12-05-2026
Lab. Reference No.	89 / 495
Date of sample collection	12-05-2026
Date of sample received	12-05-2026
Analysis start date	12-05-2026

Sample Description	Bacteriological Analysis result			
	Most Probable Number of bacteria found per 100 ml of Water Sample			
	Coliforms	Thermotolerant Coliforms	<u>E.coli</u>	Conclusion
1. Orchids – The International School, Swargate, Pune – Drinking Water Sample	0	-	-	Potable

Remark: If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

Note: Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.

Fee Rs. 340/-

Receipt No. : 7763874

Date : 12-05-2026


 Sandhya
 Chief Bacteriologist
 State Public Health Laboratory, Pune