



Office of the Chief Fire Officer
Pune Municipal Corporation
Out W.No : FB/ 2163
Date : 03/09/2024

(436/2023)

To,
Ahmad Yaar Chaudhary Architects,
Camp, Pune.

Sub:- Part Final Fire NOC for the educational building at F.P.No. 390/B, TP Scheme (No.III), Gultekadi, Pune.

(For Building Part Height-9.70 Mtrs.&Total Part Built up Area-1288.82 Sq. Mtrs. Upto Stilt floor + 1st floor only)

Ref :- i) Your Office letter Dt.28.03.2024.
ii) Provisional Fire Noc No. FB/1238, Dt.13.06.2023.
iii) Building Control Department, PMC No. CC/2010/22, Dt.02.11.2022.

Sir,

As per your request, the representative of this Fire Department has visited the proposed site along with Mr. Ahmad Yaar Chaudhary on Dt. 11.06.2024 and tested the Hydrant system, Hose Reel system with equipments and portable fire extinguishers suggested in Provisional Fire Noc No. FB/1238, Dt.13.06.2023 issued by Fire Department.

The suggestions for fire protection arrangements as mentioned in the Provisional Fire N.O.C. are made by M/s. SFS Fire Protections India Pvt. Ltd., Pune "FORM A" to that effect is submitted to this office for the fire prevention, protection & fire fighting system installed in the above said building as per The Maharashtra Fire Prevention & Life Safety Measures Act 2006. Annual fee is paid by challan No.7914, Dt.11.06.2024, Rs.12,450/-

The fire fighting equipments and systems installed in the building should be maintained in high efficiency state and in proper working order at all time during the use of the building by owner or occupier. It will be your responsibility to get the yearly renewal of this Fire NOC after due inspection from the Fire Brigade authorities. The maintenance work of the fire fighting system shall be done by the licensed contractor, having license from Director, Maharashtra Fire services. The list of the license contractor is available on www.maharashtrafireservices.org.

Name of the person, owner, responsible for the building maintenance should be informed to this office. Fire protection system provided in the building should not be removed from the building for any reason.

This Part Final No objection is subjected to any other conditions laid by any other department.

P. Patil
31/9/24

(Gajanan S. Pathrudkar)
Station Duty Officer
Pune Municipal Corporation

Copy to : Dy. Engineer (B.C.), PMC

PRINCIPAL
ORCHIDS THE INTERNATIONAL SCHOOL
SWARGATE, PUNE

M. G. Ghosh
SCHOOL MANAGER
Orchids The International School
Swargate